



Timothy Hayden, Director
Roberta L. Baker, Procurement Officer

**CALVERT COUNTY
DEPARTMENT OF FINANCE & BUDGET
PROCUREMENT OFFICE**

150 Main Street, Suite 107
Prince Frederick, Maryland 20678
410-535-1600 • 301-855-1243
www.calvertcountymd.gov

Board of Commissioners
Earl F. Hance
Mike Hart
Thomas E. Hutchins
Kelly D. McConkey
Steven R. Weems

October 26, 2020

**ITB 2020-108
CONSTRUCTION OF PROGRAM SPACE
CALVERT COUNTY DETENTION CENTER
BARSTOW, CALVERT COUNTY, MARYLAND**

QUESTIONS AND ANSWERS/CLARIFICATION NO. 4

Following are questions and answers/clarification for the above-referenced Request for Proposal. Acknowledge receipt of this document by executing the signature block provided on each page. **This completed and signed document should be included with your bid.** Failure to do so may subject bidder to disqualification.

1. Calvert County Government's further clarification on answers previously supplied in Questions and Answers/Clarification No. 3.

**Question #13. Unit pricing shall only be for unexpected conditions.
Question #14. Unit pricing shall only be for unexpected conditions.**

2. Also, on the BACnet Conformance Statement, I am not sure exactly what this is. Can you please help me understand what this is? I do not see a form in the bid documents for it. **The BACnet is intended to provide communications in a compatible language for automatic temperature controls between the proposed HVAC equipment and the existing Building Management System. The statement is a confirmation that the ATC system proposed by the Contractor shall perform as stated herein.**
3. Item #6 on page 9 of the RFP states "BACnet™ Conformance Statements" is to be included. Is there a specific form that we are to submit or are you just looking for a statement on our letter head that we will abide by their standards? Can you guide us in the right direction? **No standard form is provided. However, the statement shall include conformance to the requirements for the equipment, systems and function in accordance with this specification section.**
4. If these statements are required by the county, can they be provided after the bid opening? **Section 230900 Automatic Temperature Control, Part 2, Section 2.1 Building Management System, G.6, requires submission of the conformance statement 10 days prior to bidding. Revise this requirements to state "The Contractor shall be required to submit the conformance statements within ten (10) days of Notice to Proceed." See Addendum No. 3.**

CONTRACTOR'S LEGAL BUSINESS NAME: _____

AUTHORIZED SIGNATURE: _____ DATE: _____

Mailing Address: 175 Main Street, Prince Frederick, Maryland 20678
Maryland Relay for Impaired Hearing or Speech: 1-800-735-2258