

2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 07/02/2025	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
---------------------------------------	---------------------------------	----------------------------------	--------------------------------

6. ISSUED BY NPS, NER - NE MABO Boston National Historical Park Charlestown Navy Yard Building I-1 Boston MA 02129-4543	7. ADMINISTERED BY (If other than Item 6)
--	---

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	(x)	9A. AMENDMENT OF SOLICITATION NO. 140P4325R0030
	x	9B. DATED (SEE ITEM 11) 06/10/2025
		10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 13)

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended. is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)
Renovate Visitor Center Restrooms at Thomas Stone National Historic Site

The purpose of this Amendment is to provide a response to additional questions received.

Therefore:

- A response to additional questions received is incorporated into this Amendment.
Period of Performance: 08/01/2025 to 11/30/2025

Except as provided herein, all terms and conditions of the document referenced in Item 9 A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Jason Albright
15B. CONTRACTOR/OFFEROR <i>(Signature of person authorized to sign)</i>	15C. DATE SIGNED
	16B. UNITED STATES OF AMERICA <i>(Signature of Contracting Officer)</i>
	16C. DATE SIGNED

DESCRIPTION OF AMENDMENT/MODIFICATION

The following are a list of questions received for the Solicitation Number 140P4325R0030, Renovate Visitor Center Restrooms at Thomas Stone National Historic Site.

- 1) Oracle Lighting: If possible, can you provide me with the details for this light (listed below)?. We are unable to get a quote until we have the width, shape, direct lumens, distribution, ect... It is page 3 on the Oracle lighting cut sheet.

Example: OLS-WDI-LED-2-REC-W8-L6-D500L-HEX-GD-U500L-DIM10-MVOLT-35K-85-WH

The cut sheet provides a comprehensive list of specifications for the OLS-WDI-LED lighting series. Key sections include:

- SERIES:** OLS-WDI-LED (Oracle Wall Mount Direct/Indirect LED Linear)
- WIDTH:** 2'-2" or 4'-4"
- SHAPE:** S - Single Unit, CR - Continuous Run, CUS - Custom (Consult Factory)
- DIRECT LUMENS:** Ranges from 0500L to D1500L-HP.
- INDIRECT LUMENS:** Ranges from U500L to U1500L-HP.
- DISTRIBUTION:** Options include (blank) Standard, WW Wall Wash (Asymmetric), BW Bat Wing (Symmetric), RBW Regressed Bat Wing 60°, BW-90 Bat Wing 90°, ASM Asymmetric 30°, ICW Indirect Ceiling Wash 60°, and IW Indirect Wide 120°.
- DIMMING:** DIM10 (0-10V Dimming), DIMST (Step Dimming), LUTN (Lutron HLam), LUTFB (Lutron Fade to Black), ELD010-1-LIN (EldoLED 0-10V), DALL1 (EldoLED DALI Type 8), ELDO0MX (EldoLED DMX), DIMTR (Trac & ELV**), DIM10-0-ON (Program DIM10 to off with linear dimming curve), POE (Power Over Ethernet), EID010-LOG (EldoLED 0-10V with logarithmic dimming curve), BLE (Wireless Bluetooth Control), XSR (Titanium SR Dimming), DIM10-AUX (0-10V with Auxiliary power).
- VOLTAGE:** 120, 277, 30K, 347*, 40K, 50K.
- CCT:** 27K, 30K, 347*, 40K, 50K.
- CRI:** 85, 90.
- FINISH:** WH - White, SI - Silver, BK - Black, RAL - Consult factory.
- EMERGENCY:** O-EMG-LED-10W, O-EMG-LED-20W, O-EMG-C*, O-EMG-LED-G2-10W-SDT**, GTD-U1924 (located in GTD factory intakes on drive input).
- NUMBER OF CIRCUITS:** 1C (Up and Down Lights Controlled Together), 2C (Up and Down Lights Controlled Individual).
- OTHER OPTIONS:** FRP - Internal Fast Blow Fuse, SBP - Internal Slow Blow Fuse, RIS - Radio Interf. Sensor, BABAA - Buy America Act, BKC - Black Case, SLE - Silver Case.

Answer: Each bathroom will have OLS-WDI-LED light fixtures, Finish White, 2 ea. 8 ft. long wall mounted end to end, 4" width, S-single unit shape, D500L direct lumens, Standard Distribution, Chrome Blade Louver.

- 2) ASI Accurate Partitions- Color Selection Guide- Do you have a selected color for the Solid Plastic (HDPE) Partitions?

Answer: OLIVE 9223.

- 3) Daltile- Any details on the Color Palette, Wall Tile, or Jolly Trim? The color of the wall tile will determine the availability, and Lead Time.

Answer: Composition - Color Providential, 12x24 Wall Tile

Harmonist - Color Amity, 12x12 Floor Tile

Jolly Trim - Brushed Stainless Steel.

- 4) Are there any cut sheets for the Doors? Or will that be provided? I have the LCN Swing Operator Models 9130,9140,9150. Wasn't sure what door goes with this swing operator. Please advise.

Answer: The Government does not have a Door Cut Sheet, but they are 3'-0" x 6'-8" stand flush metal doors. The existing doors and hinges are in good shape and will remain. The existing closers will be removed, and new automatic operator will be installed, with push button.